

## No. 1140851.5R

(Please quote this number in all correspondence)

CLIENT:

SAMPLE RECEIVED FROM: At Work

Date: 14.6.16

At Work

PO Box 37 378 Parnel, Auckland

SAMPLE DESCRIPTION:

Woven green fabric "Weave In/Out" for upholstery and

panel, 93% Wool 7% Nylon, 726 g/lineal metre.

Attn.:

Client Order No.:

Client Reference:

1 of 2

AS/NZS 1530.3 - 1999 Methods for Fire Tests on Building Materials, Components and Structures Part 3: Simultaneous Determination of Ignitability, Flame Propagation, Heat Release and Smoke Release

Face Tested:

Face

	Standard Error	Mean	
Ignition Time Flame Propagation Time Heat Release Integral Smoke Release, log d Optical Density, d	Nil Nil Nil 0.0243	Nil min. Nil sec. Nil kJ/m² -1.2492 0.0568 / metre	
Number of Specimens Ignited Number of Specimens Tested		0 6	
Regulatory Indices: Ignitability Index Spread of Flame Index Heat Evolved Index Smoke Developed Index		0 0 0 3	Range 0-20 Range 0-10 Range 0-10 Range 0-10

This test was carried out by a sub-contracted laboratory.

"THIS REPORT APPLIES ONLY TO THE SAMPLES TESTED"

Except where the sample is drawn independently by NZWTA Ltd. NZWTA Ltd. makes no warranty, implied or otherwise as to the source of the tested sample. The above test results are not certified due to the adoption of modified and/or non-standard procedures designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY. Except where precluded by law, no responsibility can be accepted by NZWTA Ltd for any claim which may arise from any person acting on information contained herein.

L A Greer Signatory C Judan Signatory

11/07/2016

Ahuriri, Napier 4144, New Zealand

T+64 6 835 1086, F+64 6 835 6473 Email: testing@nzwta.co.nz



1140851.5R No.

(Please quote this number in all correspondence)

CLIENT:

SAMPLE RECEIVED FROM:

Date:

At Work

14.6.16

PO Box 37 378

At Work

Parnel, Auckland

SAMPLE DESCRIPTION:

Attn.:

Woven green fabric "Weave In/Out" for upholstery and

panel, 93% Wool 7% Nylon, 726 g/lineal metre.

Client Order No.:

Client Reference:

2 of 2

These results only apply to the specimen mounted, as described in this report. The result of this fire test may be used to directly assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all fire conditions.

The reaction of thin unsupported flexible materials to flame impingement can be assessed in accordance with AS 1530.2. Where materials of thickness less than 2mm that are sufficiently flexible to be bent by hand around a mandrel of 2mm diameter or less are subjected to the test described herein, they should also be subjected to the test in AS 1530.2.

Ignition is initiated by a pilot flame that is held near, but does not touch the specimen. A material that does not ignite during the standard test may ignite if contacted with a pilot flame during the test.

Each test specimen had an unattached backing of 4.5mm thick fibre reinforced cement board.

Each test specimen was restrained on the exposed face by a layer of galvanised welded square mesh made from wire of nominal diameter 0.8mm and nominal spacing 12mm in both directions and securely fixed to a backing board at four points each 100mm from the centre of the sample and the assembly clamped in four places.

To allow free movement of the sample during testing all corners were folded away from the clamps.

"THIS REPORT APPLIES ONLY TO THE SAMPLES TESTED"

Except where the sample is drawn independently by NZWTA Ltd. NZWTA Ltd. makes no warranty, implied or otherwise as to the source of the tested sample. The above test results are not certified due to the adoption of modified and/or non-standard procedures designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY. Except where precluded by law, no responsibility can be accepted by NZWTA Ltd for any claim which may arise from any person acting on information contained herein.

L A Greer Signatory

Judan Signatory 11/07/2016